

Dan Modeen

From: Dan Modeen [dmodeen@trust-master.com]
Sent: Thursday, February 15, 2007 10:55 AM
To: Michelle Ennen (mennen@startribune.com)
Cc: Mike Salentine (operations)
Subject: Trust Master eHOMEMANAGE Maintenance Alert

Dear Michelle Ennen:

This email is being sent to you to alert you of potential damage that might occur to your home if the following home maintenance is not address. This email has been automatically generated from your eHOMEMANAGE Home Profile Note Center:

Number/Section: 8.3/Gutters & Downspouts

Note Class: Maintenance

Description: Water and ice is overflowing onto the wood pillar on the right-front of the house. Wet rot has the potential to occur over time if water is not diverted away from the pillar. Homeowner will be notified and propose a diverter to be installed on the roof line.

Feel free to contact your Trust Master Home Management technician with any questions.

Your assigned Home Management Technician is:

DAN MODEEN
Phone: 763-213-0700
Cell: 763-228-0231
Email: dmodeen@trust-master.com

This is a post only mailing - please do not reply to this message.